



State of Ohio Environment



\* OH 4 2 0 2 3 1 2 1 5 2 0 1 1 N O V \*

## STREET ADDRESS:

**Central District Office**

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

January 5, 2011

Re: **Knox County  
Martinsburg Village PWS  
Community PWS  
PWS ID #OH4202312**

Martinsburg Village PWS  
P.O. Box 128  
Martinsburg, OH 43037

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Lead and Copper**

Your public water system is in violation of Rule 3745-81-80 through 3745-81-89 of the Ohio Administrative Code for failure to comply with the lead and copper monitoring requirements:

<b>Monitoring Period:</b>	<b>June 1 - September 30, 2010</b>
<b>Required Sampling:</b>	<b>5 samples for each lead and copper</b>
<b>Sample Results Submitted:</b>	<b>None</b>

<b>Actions required as a result of the above violation</b>	
Step 1	Collect and analyze the required number of lead and copper tap samples during June 1 - September 30, 2011. Based upon the reported population, you are required to collect a minimum of 5 lead and copper samples. Report results on the enclosed forms 5105, 5106 and 5107 by October 10, 2011.
Step 2	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> <li>mail or other direct delivery to each customer receiving a bill and to other service connections; and</li> <li>if necessary, the system must also use any other method reasonably calculated to reach all persons.</li> </ol> <p>Note: Systems opting to include the required public notice in the next water bill have up to 90 days.</p> <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Martinsburg Village PWS  
Page -2-

If you have any questions, please contact me at (614) 728-3864.

Sincerely,

A handwritten signature in cursive script that reads "Carolyn O'Neal". The signature is written in black ink and is positioned below the word "Sincerely,".

Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Knox County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File

CO/ct 4202312\_52-2010