



**Environmental
Protection Agency**

John E. Kasich, Governor

Mary Taylor, Lt. Governor

David L. Blythe, Director



February 1, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Jack C. Enberg
Lake Cha-Vel
16020 State Rte 45, Lot P1,
Wellsville, OH 43968

COLUMBIANA COUNTY
LAKE CHA-VEL
NON-COMMUNITY, TRANSIENT PWS
PWS ID # OH1557112

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Dear Mr. Enberg:

Lake Cha-Vel is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period:	October-December of 2011
Required Coliform Monitoring:	1 routine per QT
Sample Results Submitted:	0

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

As stated in a letter sent July 14, 2011, a routine sample was collected from your facility on June 29, 2011, and determined total coliform positive. OAC Rule 3745-81-21 requires four repeat samples to be collected in a timely fashion and on the same day upon notification of the positive routine sample result(s). Lake Cha-Vel failed to collect the four required repeat samples and therefore is in violation of the OAC. A public notice water use advisory was required to be issued because of this violation. The public notice for the water use advisory must remain in effect until you obtain one complete set of four repeat samples that are each determined total coliform negative.

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as is practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;
- E-mail to employees or students;
- Send to parents or guardians of children at schools or day care facilities;

- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.
2. **Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
 3. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would then be rescinded. However, a reporting violation will still remain for submitting the results late.

If you have any questions, contact me at 330-963-1293.

Sincerely,


Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Columbiana County Health Department
Rick Davis, Assistant