



FILE COPY

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

January 27, 2010

Re: Licking County
Blue Heron Manor
Community Water System
PWS ID No. 4505112
STU ID No. 4555549

Mr. Kenneth A. Kempton
LEADS
159 Wilson Street
Newark, OH 43055

Dear Mr. Kempton:

The Ohio Administrative Code (OAC) Rule 3745-83-01(C) requires that all community public water systems maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined residual at representative points in the distribution system. In section (G) (1 & 2) of the same rule, it requires the monitoring of the chlorine residual (free and combined) at least once every day when the water is available to the public at the entry point (EP001) and at a representative point in the distribution system (DS000).

A review of the December 2009 monthly operating reports Blue Heron Manor reveals that there were 22 out of the 31 days, in which the required minimum chlorine residuals were not met, monitored and/or reported properly.

Please take the necessary steps to ensure the monitoring and reporting of daily chlorine residuals (free and combined).

Sincerely,

José R. Quiñones, P.E., BCEE
Environmental Engineer
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
John L. Geller, Operator
CDO File

JQ/ct MOR-Reporting\Blue Heron 1-26-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

