

Ohio



State of Ohio Environmental Protection Agency

Central District Office

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 14, 2007

Re: Licking County
Buckeye Lake Estates MHP
Community Water System
PWS ID No. 4500012
STU ID No. 4555511

Mr. Ron Younkin
GTS Investments
555 Greenlawn Avenue
Columbus, OH 43228

Dear Mr. Younkin:

The Ohio Administrative Code, Rule 3745-83-01-(G)-(1 and 2), Operational Analyses, requires that all community water systems that provide water treated with chlorine monitor for free and combined residuals at least once every day that the water is available to the public. The monitoring must be done at each entry point to the distribution system and a representative point in the distribution system. A review of August monthly operating reports for the Buckeye Lake Estates Mobile Home Park reveals that there were eight (8) out of the 31 days, in which chlorine residuals were not monitored and/or reported.

Please take the necessary steps to ensure that chlorine residuals are monitored and reported.

Sincerely,

José R. Quiñones, P.E.
Environmental Engineer
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
Engineering and Operations, DDAGW/CO
Sally McClintock, Manager, Buckeye Lake Estates Mobile Home Park
Gregory P. Foltz, Buckeye Lake Estates Mobile Home Park
CDO File

JRQ/nsm Buckeye Lake Estates 9-07

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

