



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

December 17, 2008

**Re: Licking County
El Rancho Mobile Home Park
Community Water System
PWS ID# OH4500512**Mr. James Croston
72046 Cooper Road
Radcliff, OH 45695**Subject: Notice of Violation for failure to maintain chlorine residuals**

Dear Mr. Croston:

The Ohio Administrative Code, Rule 3745-83-01-(B)-(2), Operational Requirements, Disinfection, requires that each community water system maintains a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system at all times. A review of November 2008 monthly operating reports for El Rancho Mobile Home Park reveals that there were four (4) out of the 30 days, in which the required minimum chlorine residuals were not met. Please take the necessary steps to ensure that chlorine residuals are maintained throughout the water distribution system as required by this rule.

Please ensure that the monthly operating reports and other reports have the correct PWS ID no. so proper credit can be given.

Sincerely,

José R. Quiñones, P.E.
Environmental Engineer
Division of Drinking and Ground Waters
Central District Officec: Licking County Health Department
Mr. Paul Hellman
CO/DDAGW
CDO File

JQ/ct Letters\Monthly-Violation\Chlorine\El Rancho 12-08

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

