



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

October 31, 2007

Re: **Licking County**
Maple Heights Mobile Home Park
Community PWS
PWS ID #4501912

Owner
 Maple Heights Mobile Home Park
 P.o. Box 4102
 Newark, OH 43058

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	September 2007
Required Coliform Sampling:	At least 1 sample(s) each month.
Sample Results Submitted:	NONE

Actions required as a result of the above violation


Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. mail or other direct delivery to each customer receiving a bill and to other service connections; and 2. if necessary, the system must also use any other method reasonably calculated to reach all persons. <p>Note: Systems opting to include the required public notice in the next water bill have up to 90 days.</p> <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of Ohio EPA.</p>

Ted Strickland, Governor
 Lee Fisher, Lieutenant Governor
 Chris Korleski, Director

Owner
Maple Heights Mobile Home Park
Page -2-

If you have any questions, please contact me at (614) 728-3869.

Sincerely,

A handwritten signature in black ink that reads "José R. Quiñones". The signature is written in a cursive style and is underlined with a single horizontal line.

José R. Quiñones, P.E.
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Licking County Health Department
Toni Buchanan, DDAGW/CO
CDO File
Maple Heights Mobile Home Park, c/o Ed & Pat Athey, Managers