



State of Ohio Environment



* 0 H 4 5 0 4 6 1 2 . 1 2 . 2 0 0 7 N O V *

STREET ADDRESS

Central District Office

MAILING ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, Ohio 43216-1049

January 2, 2007

Re: Licking County
Living Care Alternatives, Inc.
Community PWS
PWS ID #4504612
CERTIFIED #7006 2760 0001 2070 6259

Thomas J. Rosser
Living Care Alternatives, Inc.
855 South Sunbury Road
Westerville, OH 43081

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

During November 2006, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> 1. Hand delivery to employees; 2. Posting in conspicuous locations (bulletin boards, etc.); and 3. Mail to guardians of the residents <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in December 2006.

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director




Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer

Thomas J. Rosser
Living Care Alternatives, Inc.
Page -2-

If you have any questions, please contact me at (614) 728-3869.

Sincerely,

A handwritten signature in black ink that reads "Jose R. Quinones". The signature is written in a cursive style with a horizontal line underneath the name.

Jose Quinones, P.E.
Environmental Engineer
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW, CO
Licking County Health Department
CDO File
Pine Kirk Nursing Home, Administrator

JQ/nsm 4504612 NOV21 25or26 Nov. 2006