



\* 0 H 4 5 0 4 6 1 2 7 9 2 0 0 8 N O V \*

State of Ohio Environmental Protection Agency

## STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

## Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

## MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

July 9, 2008

Re: Licking County  
Pine Kirk Care Center  
Community Water System  
PWS ID No. OH4504612  
STU ID No. OH4555547

Alberta Triona  
Administrator  
Living Care Alternative of Kirkersville, Inc.  
Pine Kirk Care Center  
P. O. Box 221  
Kirkersville, OH 43033

Dear Ms. Triona:

The Ohio Administrative Code, Rule 3745-83-01-(B)-(2), Operational Requirements, Disinfection, requires that each community water system maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system at all times. A review of June 2008 monthly operating reports for the Pine Kirk Care Center reveals that there were eight (8) out of the 30 days, in which the required minimum chlorine residuals were not met, monitored and/or reported properly.

Please take the necessary steps to ensure that chlorine residuals are maintained throughout the water distribution system as required by this rule.

Sincerely,

José R. Quiñones, P.E.  
Environmental Engineer  
Division of Drinking and Ground Waters  
Central District Office

c: Licking County Health Department  
Mr. Thomas J. Rosser, Living Care Alternatives, Inc.  
CO/DDAGW  
CDO File

JQ/ct Letters\Monthly-Violation\Chlorine\Pine-Kirk

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

