



State of Ohio Environmental Protection Agency

## STREET ADDRESS:

Central District Office

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

**CERTIFIED MAIL #91 7108 2133 3932 4451 0972**

June 27, 2007

Re: Licking County  
Southwest Licking Water & Sewer District  
Community Water System  
PWS ID No. 4505412

Mr. Donald S. Rector, P.E.  
General Manager  
Southwest Licking Community Water & Sewer District  
P.O. Box 215  
Etna, OH 43018

Dear Mr. Rector:

NOTICE OF VIOLATION

This letter is notice that the Southwest Licking Community Water & Sewer District (SLCW&SD) public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 mg/L to 1.3 mg/L each and every day mentioned in the period below.

Date	Plant Tap Fluoride Level (mg/L)
January 1 through December 31, 2006	less than 0.8

The SLCW&SD can use the Consumer Confidence Report (CCR) as a means to notify their customer for this violation.


The SLCW&SD is also in violation of the phosphate and fluoride feed systems plan approval conditions. The plan was approved on July 18, 2005 under the plan approval No. 388853. Please provide this office with a schedule as to when the permanent structures for the phosphate and fluoride feed systems will be installed and operational. Although not approved per detail plans, we will allow the continued use of the phosphate feed system to minimize discolored water and minimized chlorine residual problems on temporary basis not to exceed 180 days from the date of this letter. This does not constitute an approval and the SLCW&SD will remain in violation until such permanent facilities are constructed in accordance with the approved plans.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Mr. Donald S. Rector, P.E.  
Southwest Licking Community Water & Sewer District  
Page 2  
[Type text]

If you should have any questions, please contact me directly at (614) 728-3869.

Sincerely,

A handwritten signature in cursive script that reads "José R. Quiñones." The signature is written in black ink and is positioned above a horizontal line.

\_\_\_\_\_  
José R. Quiñones, P.E.  
Environmental Engineer  
Division of Drinking and Ground Waters  
Central District Office

c: Susie Bodnar, DDAGW, CO  
Perry Adkins, SLCW&SD  
CDO File