




State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 18, 2007

Re: Madison County
Greentree Mobile Home Park
Community Water System
PWS ID: 4900512

Mrs. Vicky Joos
Greentree Mobile Home Park
P.O. Box 516
Galloway, OH 43119

Dear Mrs. Joos:

Ohio EPA received the Greentree Mobile Home Park Consumer Confidence Report (CCR) for 2006 on June 19, 2007. The CCR was reviewed for the required content. Based on our review, the Greentree Mobile Home Park water system is in violation of the Ohio Administrative Code (OAC) Rules 3745-96-01 through 04 for failure to comply with the CCR requirements, the following violations were noted:

1. We have not received the CCR distribution certification form. Please submit this form within 10 days from the date of this letter.
2. Total coliform was detected in 2006. The level was omitted from the table of detected contaminants.
3. The total coliform monitoring violations for June 2006, and November 2006, were not included in the report.
4. The required health information that was required as a result of the total coliform exceedance in June 2006, was not included in the report.
5. Include Total Chlorine residual levels in the table. (These levels can be found on the Quarterly Total Chlorine Residual Quarterly Operating Report form 5114 which is on our website <http://www.epa.state.oh.us/ddaqw/drinkforms.htm>.)

Be sure to correct the violation(s) as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers by no later than July 1, 2008. A copy of the CCR along with a Certification Form must be submitted to the Central

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer


Mrs. Vicky Joos
Greentree Mobile Home Park
Page 2

District Office at the above address. Violations in future reports may result in further enforcement action.

The CCR template and template guide are accessible on our website:
www.epa.state.oh.us/ddagw.

If you have any questions, please contact me at 614-728-3870.

Sincerely,

A handwritten signature in black ink, appearing to read "Bridgette Marchio". The signature is written in a cursive style with a large initial "B".

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

C: Dave Leverage, Winelco, Inc.
CDO File