



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



* 0 H 4 9 0 1 5 1 2 8 3 5 1 4 7 4 *

March 14, 2011

Re: **Madison County
Picket Fences MHP
Community Water System
PWSID: OH4901512**

Mr. Paul Bogenrife
P.O. Box 296
West Jefferson, OH 43162

Subject: Notice of Violation for Operational Requirements

Dear Mr. Bogenrife:

In accordance with Ohio Administrative Code (OAC) 3745-83-01, public water systems that are required to monitor for chlorine must do so every day that water is available to consumers.

According to your January 2011 monthly operating report chlorine residuals were not monitored during the weekends and Picket Fences is in violation of OAC 3745-83-01. I spoke to Mr. Pat Hickman, the operator of record, on March 10, 2011, to discuss the monthly report and the requirements for monitoring daily chlorine residuals.

Per OAC 3745-83-01, both you and Mr. Hickman are responsible to ensure that proper chlorine residuals are maintained throughout the distribution system. Please respond within 10 days on what corrective action you are taking to ensure that chlorine residuals are checked and recorded during the weekends.

If you have any questions, please call me at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: **Madison County Health Department
Pat Hickman, Operator
CDO File**

BM/ct Picket Fences January 2011 violation MOR

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov