

SIGNATURE RECEIVE
Ohio

State of Ohio Environmental Protection Agency

Central District Office

COPY

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

August 13, 2007

Re: **Madison County
Rosedale Bible Institute
Community PWS
PWS ID #4902112
CERTIFIED #91 7108 2133 3932 4451 0132**President
Rosedale Bible Institute
2270 Rosedale Road
Irwin, OH 43029**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation

Step 1

Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. Each total coliform positive ROUTINE sample must be followed by four (4) repeat (*check*) samples. Repeat samples shall be collected within twenty-four (24) hours of being notified of the routine coliform positive result and shall not exceed 14 days from the positive routine sample collection date. Repeat samples shall be collected at the following locations:

- 1) The same tap as the original positive result;
- 2) A tap within 5 taps upstream of the original positive tap;
- 3) A tap within 5 taps downstream of the original positive tap;
- 4) A tap within 5 taps either upstream or downstream of the original positive.


Each set of four (4) repeat samples must be collected on the same day.Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

President
Rosedale Bible Institute
Page -2-

Step 2	Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.). The language in italics on the attached public notice is mandatory and must be included as written.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days of the issuance of the public notice to the Central District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in August 2007.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,



Bridgette Marchio
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Madison County Health Department
CDO File
Rosedale Bible Institute, Board Of Trustees