



State of Ohio Environmental Protection Agency

## STREET ADDRESS:

Central District Office

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

<b>NOTICE OF VIOLATION - ACTION REQUIRED</b>
--

July 1, 2010

Re: **Morrow County**  
**Lakeview Estates Mobile Home Park**  
**Community**  
**PWS ID: OH5900512**

Nicholas A. Kukul  
P.O. Box 41033  
Brecksville, OH 44141

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)**  
**During June 2010 (Monthly)**

Lakeview Estates Mobile Home Park is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**


1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Mail or other direct delivery to each customer;
  - If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Kortleski, Director

Nicholas A. Kukul  
Page -2-

If you have any questions, contact this office at 614-728-3864.

Sincerely,



Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

c: Morrow County Health Department  
Information Management Section, DDAGW/CO  
District File Copy