



State of Ohio Environmer.



STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3776 FAX: (614) 728-3896
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

August 19, 2008

Re: **Pickaway County
Village of Ashville
Community Water System
PWSID: 6500012**

Franklin Christman
Village Administrator
Village of Ashville
200 Station Street
Ashville, OH 43103

Re: **Notice of Violation for Operational Requirements**

Dear Mr. Christman:

In accordance with Ohio Administrative Code (OAC) 3745-83-01, public water systems that are required to monitor for iron, manganese, and hardness must monitor for these parameters by the following methods:

For Iron and manganese:

1. Use an in-house test kit to monitor the iron and manganese concentrations daily at each entry point into the distribution system. Have one split sample analyzed monthly by the in-house test kit and by a certified laboratory. Verify that the deviations between the results are no greater than 0.2 mg/L for iron and 0.04 mg/L for manganese; or
2. Monitor for iron and manganese at least *weekly* at each entry point into the distribution system using a state certified laboratory.

For hardness:

1. Monitor for hardness at least *weekly* at each entry point into the distribution system using a state certified laboratory.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Franklin Christman
Village of Ashville
Page -2-

According to the July 2008 Ashville monthly operating report, the village submitted five samples that were all collected prior to the 15th of the month constituting a violation of OAC 3745-83-01.

If you have any questions, please call me at (614) 728-3870.

Sincerely,

A handwritten signature in cursive script that reads "Bridgette Marchio".

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Pickaway County Health Department
James Welsh, Operator, Village of Ashville
CDO File

BMct AshvilleJulyviolation MOR