



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3998
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049**CERTIFIED MAIL # 91 7108 2133 3932 4450 1208**

January 2, 2009

**Re: Pickaway County
City of Circleville
Community Water System
PWS ID# 6500412
STU ID# 6557171**Mr. Paul Jacobs
Superintendent
Circleville Water & Sewer Maintenance
108 E. Franklin Street
Circleville, OH 43113

Dear Mr. Jacobs:

On November 24, 2008, this office received a backflow program implementation schedule from you. The schedule was a requirement outlined in the Circleville sanitary survey letter dated July 15, 2008. On November 18, 2008, Ohio EPA issued Director's Unilateral Findings and Orders (enclosed) to the City of Circleville. Order No. 3 specifies what is required in order for the City to comply with backflow regulations. The schedule and information that you submitted to my office does not satisfy the requirements in the Findings & Orders.

To comply with the Unilateral Findings & Orders, the following must be submitted to Ohio EPA:


1. A listing of all active accounts with testable backflow devices located within the distribution system and the current status of each device. For any device not working or that has not been tested, provide an implementation schedule of corrective actions that will be taken;
2. An implementation schedule on addressing any remaining businesses that may need backflow devices;
3. An implementation schedule to address residential accounts that may need backflow protection; and
4. The implementation schedules shall identify the person(s) who will oversee the backflow program, and how much time per week will be dedicated to implementing the program.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Mr. Paul Jacobs
Circleville Water & Sewer Maintenance
Page -2-

According to the Unilateral Findings and Orders, all of the above information is to be submitted to my office by January 17, 2009. If you have any questions regarding this matter, feel free to contact me at 614-728-3870 or Susan Hampton at 614-728-5033.

Respectfully,



Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Charles Taylor, Circleville Mayor
Terry Elliott, Circleville Public Service Director
David Crawford, Circleville Council President
Ronald Stephens, Circleville Water Plant Superintendent
Central Office/DDAGW/CMCU
CDO File