



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 11, 2010

Re: Pickaway County
City of Circleville
Community Water System
PWS ID: OH6500412

The Honorable Charles Taylor
Mayor
City of Circleville
130 S. Court Street
Circleville, OH 43113

Subject: Notice of Violation for Manganese and Iron

Dear Mayor Taylor:

According to the City of Circleville monthly operating reports submitted for January 2010, one of the four finished water quality samples exceeded the secondary maximum contaminant levels (MCL) for manganese and iron. On January 25, 2010, the iron and manganese concentrations in the finished water were 0.33 mg/l and 0.08 mg/l; respectively. Each exceedance is a violation of Ohio Administrative Code 3745-82-02.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Pickaway County Health Department
Ron Stephens, Circleville Water Superintendent
Todd Kelleher, DDAGW/CO, CMCU
Dave Bornino, DDAGW/OFA
CDO File

BM/ct Circleville January 2010 manganese and iron violation

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director