



State of Ohio Environmental Protection Agency, 5004126252010NOV*

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

June 25, 2010

Re: **Pickaway County
City of Circleville
Community Water System
PWS ID: OH6500412**

Honorable Charles Taylor, Mayor
City of Circleville
130 S. Court Street
Circleville, OH 43113

Subject: Notice of Violation for Manganese

Dear Mayor Taylor:

According to the City of Circleville monthly operating reports submitted for May 2010, two of the five finished water quality samples exceeded the secondary maximum contaminant levels (MCL) for manganese. On May 10, 2010, the manganese concentration in the finished water was 0.07 mg/l and on May 31, 2010, it was 0.08 mg/l. Each exceedance is a violation of Ohio Administrative Code 3745-82-02.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Pickaway County Health Department
Phil Salyers, Circleville Service Director
Ron Stephens, Circleville Water Superintendent
Todd Kelleher, DDAGW, CO, CMCU
Dave Bornino, DDAGW, OFA
CDO File

BM/nsm Circleville May 2010 manganese violation

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director