



State of Ohio Environmental Protection Agency

## STREET ADDRESS:

Central District Office

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

October 5, 2010

Re: Pickaway County  
City of Circleville  
Community Water System  
PWS ID: OH6500412

The Honorable Charles Taylor  
Mayor  
City of Circleville  
130 S. Court Street  
Circleville, OH 43113

**Subject: Notice of Violation for Iron and Manganese**

Dear Mayor Taylor:

According to the City of Circleville monthly operating reports submitted for August 2010, all five finished water quality samples exceeded the secondary maximum contaminant levels (SMCL) for manganese and one of the five samples exceeded the SMCL for Iron. The following table shows the sample date, the parameter and the finished water concentration in mg/l:

Sample Date	Parameter exceeded Mn or Fe	Concentration (mg/l)
August 2, 2010	Mn	0.10
August 9, 2010	Mn	0.07
August 16, 2010	Mn	0.17
August 16, 2010	Fe	0.50
August 23, 2010	Mn	0.10
August 31, 2010	Mn	0.16

Each exceedance is a violation of Ohio Administrative Code 3745-82-02.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Pickaway County Health Department  
Robert Evans, Circleville Service Director  
Ron Stephens, Circleville Water Superintendent

Todd Kelleher, DDAGW/CO/CMCU  
Dave Bornino, DDAGW/OFA  
CDO File

BM/ct Circleville August 2010 manganese and iron violation

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director