



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

**CERTIFIED #91 7108 2133 3932 4450 9327**

August 23, 2007

**Re: Pickaway County  
Commercial Point  
Community Public Water System  
PWS ID: 6503512**

Doug Hartman  
Village of Commercial Point  
P.O. Box 78  
Commercial Point, OH 43146

Dear Mr. Hartman:

The Village of Commercial Point is in violation of Ohio Administrative Code (OAC) 3745-81-87 (B) for failure to conduct water quality parameter sampling.

As stated in our April 27, 2007, letter the Village of Commercial Point public water system exceeded the action level for lead in the June -September 2006 monitoring period. By no later than June 30, 2007, the water system was required to do the following:

1. Take a set of water quality parameters from one distribution site two times.
2. Take one set of water quality parameters from the entry point into distribution one time.
3. Take one flushed entry point sample for lead and copper.
4. Educate the consumer about lead in drinking water.

Please follow the directions in our April 27, 2007, letter (enclosed) and submit the required information immediately and by no later than September 3, 2007.

Note: A 141-C form must also be completed and detail plans must be submitted (if necessary) by no later than October 31, 2007. We will assist you with the 141-C form upon request.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfeski, Director

Doug Hartman  
Village of Commercial Point  
Page -2-

If you have any questions, or need additional forms, please call me at (614) 728-3864 or email [carolyn.oneal@epa.state.oh.us](mailto:carolyn.oneal@epa.state.oh.us).

Sincerely,



Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

Enclosure: April 27, 2007, letter

c: Pickaway County Health Department  
John Grosse, Operator of Record  
Bridgette Marchio, DDAGW/CDO  
Engineering & Operations, DDAGW/CO  
CDO File

CO/nsm CommercialWQPvio