

SIGNATURE RECEIVED

6/15/10

Ohio

State of Ohio Environment



STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4449 4234

June 8, 2010

**Re: Pickaway County
Crossroads MHP
Community Water System
PWS ID: 6500612
STU ID: 6557172**

Mr. Willis Hunley
Crossroads MHP
1015 US Highway 22
Apt 5
Circleville, OH 43113

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Mr. Hunley:

This letter is notification that the Crossroads MHP has not complied with requirements issued during this Agency's last survey performed on February 23, 2010, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated April 12, 2010, to respond in writing no later than 45 days, with time frames for:

1. Hiring a Class A operator to oversee the MHP's public water system facility.
2. Monitoring and maintaining adequate free and combined chlorine residuals within the water treatment plant and distribution system of the park.
3. Utilizing the appropriate monthly operating report that was included with my survey packet.
4. Updating the current contingency plan to address all the requirements as outlined in the survey letter.
5. Maintaining operations and maintenance records for your facility in accordance with OAC 3745-7-09.
6. Providing documentation that your DPD chlorine test kit has had a calibration check performed on it by a state certified laboratory.
7. Install an anti-siphon valve on the chlorine pump.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

CONFIDENTIAL


Mr. Willis Hunley
Crossroads MHP
Page -2-

8. Repair electrical conduit on well no.1.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,



Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Pickaway County Health Department
C.O. - DDAGW / OFAS
CDO File