

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL #7006 2760 0002 9658 0097

April 12, 2007

RE: Pickaway County
Crossroads Mobile Home Park
Community Water System
PWS ID: 6500612
STU ID: 6557172

Mr. Willis Hunley
1015 US 22, Apt. #5
Circleville, OH 43113

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Crossroads Mobile Home Park has not complied with requirements issued during this Agency's last survey performed on August 29, 2006, in violation of rule 3724-81-60 of the Ohio Administrative Code. The water system was notified in correspondence dated September 28, 2006, to respond in writing no later than 45 days, with time frames for:

- Installing new vented well caps that fit securely to the top of the well casings and be secured with screws or other appropriate connections.
- Provide documentation that the 12.5% chlorine solution that you are using is an ANSI/NSF approved chemical.
- Maintaining minimum chlorine residuals of at least two-tenths milligram per liter free chlorine, or one milligram per liter combined chlorine measured at representative points throughout the distribution system.
- Provide an updated written contingency plan as required by OAC 3745-85.

I made an error in my survey letter by not including failure to submit monthly operating reports to my office under the *Requirements* section of the letter. You are required to submit Ohio EPA form 5002 (enclosed) every month. The information that you are required to report is highlighted on the form. Begin submitting the monthly reports in May 2007. The May report will be due in my office by June 10, 2007. Additional forms are available online at http://www.epa.state.oh.us/ddagw/Documents/MOR_PLANTDIST.PDF.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Mr. Willis Hunley
Page -2-

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to respond may result in further enforcement action.

If you have any questions, please contact me at (614) 728-3870.

Sincerely,



Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

Enclosure

c: Pickaway County Health Department
CO/DDAGW/OFAS
CDO File