



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)P.O. Box 1049  
Columbus, OH 43216-1049

June 19, 2009

**Re: Pickaway County  
Crossroads MHP  
Community Water System  
PWS ID# 6500612  
STU ID# 6557172**Mr. Willis Hunley  
1015 US 22, Apt. #5  
Circleville, OH 43113

Dear Mr. Hunley:

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G)(1) & (2) requires the public water system owner to monitor for free **and** combined chlorine residuals at least once every day at the plant tap and within the distribution system (at a residents home). According to your monthly operating reports you have only been reporting the combined chlorine residual.

Please correct this deficiency by reporting both the free and combined chlorine residuals beginning in July 2009. If you have any questions, feel free to contact me at 614-728-3870.

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Officec: Pickaway County Health Department  
CDO File

BM/ct CrossroadsMHPJune2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer