



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

November 1, 2007

**Re: Pickaway County
Village of Darbyville
Community Water System
PWS ID: 6503412**Village Council
Village of Darbyville
16671 Main Street
Williamsport, OH 43164

Dear Council:

This letter is to inform you of deficiencies on the monthly operating report submitted to our office for the Village of Darbyville. **Ohio Administrative Code (OAC) 3745-83-01 requires you to maintain (daily) a free chlorine residual of 0.2 mg/L or a combined chlorine residual of 1.0 mg/L in the distribution system at all times.** There were 15 days in the month of September 2007, where minimum required chlorine residuals were not maintained and the Village of Darbyville was in violation of OAC 3745-83-01.

Please take whatever means necessary to correct the problem of low chlorine residuals within the distribution system. If you have any questions, please call me at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Officec: Pickaway County Health Department
Mr. Bill Eitel, Water Specialists, Inc.
CDO File

BM/ct darbyvilleOctober 29

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director