

*pages 1 of 2*



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728 3896  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 25, 2008

**Re: Pickaway County  
Meadowbrook Village MHP  
Community Water System  
PWS ID: 6501812**

Mr. Sam Misuraca  
Oak Ridge Communities  
301 West Fourth Street  
Royal Oak, MI 48067

Dear Mr. Misuraca:

This letter is to inform you of deficiencies on the monthly operating report submitted to our office for the Meadowbrook Village MHP. **Ohio Administrative Code (OAC) 3745-83-01 requires you to maintain (daily) a free chlorine residual of 0.2 mg/L or a combined chlorine residual of 1.0 mg/L in the distribution system at all times.** There were nine days (on weekends) in the month of June 2008, where minimum required chlorine residuals were not monitored/recorded and the Meadowbrook Village MHP was in violation of OAC 3745-83-01.

Please take whatever means necessary to correct the problem of not monitoring chlorine residuals within the distribution system. If you have any questions, please call me at (614) 728-3870.

Sincerely,

**Bridgette Marchio**  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

**RECEIVED**

**JUL 31 2008**

**OHIO EPA/CDO**

c: Pickaway County Health Department  
Manager, Meadowbrook Village MHP  
Winelco Inc.  
CDO File

BM/cd MeadowbrookVillageJune2008

Gov. Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



page 2 of 2 Meadowbrook Village

	T	F
June 1 -	.7	.6
7 -	.6	.6
8 -	.7	.6
14 -	.7	.7
15 -	.6	.6
21 -	.7	.7
22 -	.8	.7
28 -	.7	.6
29 -	.7	.6

RECEIVED  
 JUL 31 2008  
 OHIO EPA/CDO

100

100