



State of Ohio Environment



## STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

## Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

## MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 28, 2009

Re: Pickaway County  
Village of South Bloomfield  
Community Water System  
PWS ID: 6502112

Mr. Joe Allen  
Village of South Bloomfield  
5023 S. Union Street  
South Bloomfield, OH 43103

Dear Mr. Allen:

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. According to the Village's July 2009 monthly operating report, the chlorine residuals were below the minimum levels within the distribution system for ten days during the month.

You are required to make corrective actions to ensure that proper chlorine residuals are maintained within the Village's distribution system. If you have any questions, please call me at (614) 728-3870.

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Pickaway County Health Department  
CDO File

BM/ct South Bloomfield July 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer

1-10-1