



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

August 19, 2008

**Re: Pickaway County
Sunset Mobile Home Park
Community Water System
PWS ID: 6502412
STU ID: 6557187**Mr. Clifford Hill
9737 Anderson Antioch Road
Mt. Sterling, OH 43243

Mr. Hill:

Per our telephone conversation on August 13, 2008, the "arsenic" filter that you installed at the water treatment plant at Sunset Mobile Home Park was done without receiving plan approval from Ohio EPA and is a violation of Ohio Administrative Code (OAC)3745-91-02.

Any treatment that you installed without plan approval must be removed or at a minimum bypassed until plan approval is achieved. Arsenic is a primary contaminant (health based) and any treatment installed at a public water system to remove it must be approved by Ohio EPA. The plans that you need to submit are required to be prepared and issued by a registered professional engineer (P.E.). Please note that pilot testing (or demonstration testing) is required for treatment processes which have not been sufficiently used in the state of Ohio to demonstrate effectiveness.

I highly recommend that you contact my office requesting a meeting with our engineering department to discuss your treatment options as soon as possible. In the interim, you should continue monitoring arsenic quarterly at the entry point into the distribution system.

Sincerely,

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Officec: Pickaway County Health Department
Kathy Pinto, DDAGW/CO
CDO File

BN/ct SunSetMHPArsenicFilterViolationAugust2008

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Koleski, Director

