



State

## STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

## Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

## 3 ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

November 15, 2010

Re: **Pickaway County  
Twin Pines MHP  
Community PWS  
PWS ID #OH6501312**

Twin Pines MHP  
9859 Shepherd Road  
Lot 27  
Lockbourne, OH 43137

**Subject: Notice of Violation - Failure to Submit Operational Reports**

A review of our records indicates that the operational reports for Twin Pines MHP public water system have not been submitted for September 2010. This failure to submit reports constitutes a violation of the Ohio Administrative Code, Rule 3745-81-31 and Section 6109.12 of the Ohio Revised Code.

Reports required to be completed and submitted to Ohio EPA include:

1. Plant-Distribution Monthly Operation Report, EPA form 5002
2. Total Chlorine Residual Quarterly Operating Report, EPA form 5114

The required reports must be completed and submitted to this office by the tenth of the month following the reporting period. All required reports for the reporting period September 2010 must be forwarded to my attention within 15 days.

If you have any questions, please contact me at (614) 728- 3870.

Sincerely,

Bridgette Marchio  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

## Enclosures

c: Pickaway County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File

BM/cl 6501312 MOR Sep10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

