



State of Ohio Environmental



STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 10, 2010

Re: **Pickaway County
Wagon Wheel MHP
Community Water System
PWS ID: 6502812**

Mr. Jerry Timmons
7108 Scioto-Darby Road
Ashville, OH 43103

Dear Mr. Timmons:

This letter is to inform you of deficiencies on the monthly operating report submitted to our office for the Wagon Wheel MHP. **Ohio Administrative Code (OAC) 3745-83-01 requires you to maintain (daily) a free chlorine residual of 0.2 mg/L or a combined chlorine residual of 1.0 mg/L in the distribution system at all times.** There were six days in the month of July 2010, where minimum required chlorine residuals were not maintained and the Wagon Wheel MHP was in violation of OAC 3745-83-01.

Please take whatever means necessary to correct the problem of low chlorine residuals within the distribution system.

If you have any questions, please call me at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Pickaway County Health Department
CDO File

BM/ct WagonWheelMHP July 2010 Cl violation

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director