



State of Ohio Environmental

* 0 H 8 0 0 0 3 1 4 8 1 7 1 3 0 8 *

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049**NOTICE OF VIOLATION - ACTION REQUIRED**

September 9, 2008

Re: **Union County
City of Marysville
Public Community
PWS ID No.: OH8000314**John Mitchell
Public Service Director
City of Marysville
125 East Sixth Street
Marysville, Ohio 43040-1641**Subject: Individual Filter Effluent Monitoring**

The Ohio Administrative Code, Rule 3745-81-74-(B)-(1), requires that a public water system that provides conventional filtration treatment conducts continuous monitoring of turbidity for each individual filter effluent. A review of July 2008 monthly operating reports for the City of Marysville reveals that there were five (5) out of the 31 days, in which each of the individual filters' effluent turbidity was not monitored and/or reported.

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served. The appropriate methods for your system are listed below under the **Public Community** column.

Public Community	Transient or Non Transient Non Community
Timing: As soon as practical, but no later than one year after learning of the violation:	Timing: As soon as practical, but no later than 30 days after learning of the violation:
Methods: <ul style="list-style-type: none"> • Mail or other direct delivery to each customer; or • Annual Consumer Confidence Report provided it's distributed within one year after learning of the violation; and • If necessary to reach all persons regularly served, use other notification methods such as newspaper publication, public posting or internet posting 	Methods: <ul style="list-style-type: none"> • Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas • Mail or other direct delivery to each customer • Newsletters or newspaper • E-mail to employees or students • Send to parents or guardians of children at schools or day care facilities


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, DirectorDate Received 8/7/2008
8809001

John Mitchell
City of Marysville
Page 2

2. Complete the enclosed Verification Form within ten (10) days of issuing the Public Notice and mail it to Ohio EPA - Central District Office. Include a copy of each notice distributed, published or posted.

If you have any questions, contact this office at 614-728-3869.

Sincerely,



José R. Quiñones, P.E.
Environmental Engineer
Division of Drinking and Ground Waters
Central District Office

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

c: Union County Health Department
Engineering and Operations, DDAGW/CO
Fred McCreary, WTP Chief Operator, City of Marysville
CDO File