



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

April 27, 2007

Re: Fairfield County
Allegheny West Conf. Camp - Lake
Transient Non-Community
PWS ID #2336012

Campground Coordinator
Allegheny West Conf. Camp - Lake
1339 East Broad Street
Columbus, OH 43205

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	January - March 2007
Required Coliform Sampling:	At least 1 sample each calendar quarter.
Sample Results Submitted:	NONE


Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. Continuous posting, mail, or other direct delivery; and 2. If necessary, the system must also use any other method reasonably calculated to reach all persons. <p>The language in <i>italics</i> on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Campground Coordinator
Allegheny West Conf Camp - Lake
Page -2-

If you have any questions, please contact me at (614) 728-3871.

Sincerely,

A handwritten signature in black ink, appearing to read 'Mark Boden', with a stylized, looping flourish at the end.

Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Fairfield County Health Department
CDO File

MB/nsm 2336012 NOV23or24 Jan-Mar 2007