



State of Ohio Environmental Protection Agency

## STREET ADDRESS:

**Central District Office**

## MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049

October 16, 2007

**Re: Fairfield County  
Cudajo's  
Transient Non-Community  
PWS ID #2345812**

Cudajo's  
13607 Shell Beach Road  
Thornville, OH 43076

**Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.**

Your public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the months of July, August and September 2007, because your water system uses a source that has been designated as a surface water source and you do not provide adequate treatment. You will continue to be in violation of OAC Rule 3745-81-73 until you make modifications to your water system that would enable Ohio EPA to designate your source as ground water or until you install surface water treatment that meets the requirements of OAC Rule 3745-81-71 thru 3745-81-74.

| <b>Actions required as a result of the above violation</b> |  |
|--|--|
| Step 1   | <p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>1. posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in <i>italic</i> on the attached public notice is mandatory and must be included as written.</p> |
| Step 2   | Initiate an investigation and take the necessary steps to correct the problem as soon as possible.   |
| Step 3   | Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.  |

If you have information, questions or have completed modifications to your system that you believe will bring your system into compliance, please contact me at (614) 728-3871.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Cudajo's  
Page -2-

Please note that the Ohio EPA can pursue civil penalties of up to \$25,000.00 per day per violation pursuant to Chapter 6109 of the Ohio Revised Code.

Sincerely,



Susan Applegate  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Fairfield County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File

SH/vt CuDaJosGWU10Oct2007