



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

August 2, 2007

**Re: Fairfield County
Cudajo's
Transient Non-Community
PWS ID #2345812**

Cudajo's
13607 Shell Beach Road
Thornville, OH 43076

Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.

Your public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the month of April, May, June 2007, because your water system uses a source that has been designated as a surface water source and you do not provide adequate treatment. You will continue to be in violation of OAC Rule 3745-81-73 until you make modifications to your water system that would enable Ohio EPA to designate your source as ground water or until you install surface water treatment that meets the requirements of OAC Rule 3745-81-71 thru 3745-81-74.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>
Step 2	Initiate an Investigate and take the necessary steps to correct the problem as soon as possible.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.


If you have information, questions or have completed modifications to your system that you believe will bring your system into compliance, please contact me at (614) 728-3871.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Cudajo's
Page -2-

Please note that the Ohio EPA can pursue civil penalties of up to \$25,000.00 per day per violation pursuant to Chapter 6109 of the Ohio Revised Code.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Fairfield County Health Department
CDO File

MB/nsm CuDaJosGWUI