



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

SIGNATURE RECEIVED

4/6/11

FILE COPY

OH2332212 GENEVA HILLS RESIDENCE

21 03/21/11

CERTIFIED MAIL # 91 7108 2133 3932 44



NOTICE OF VIOLATION – NO IMMEDIATE ACTION REQUIRED

March 22, 2011

Re: **Fairfield County**
Geneva Hills Residence
Non-Community, Transient
PWS ID: OH2332212

Geoffrey Burns
1380 Blue Valley Road
Lancaster, OH 43130-9021

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2010 (ACUTE)**

Geneva Hills Residence was in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. coli*/fecal coliform in the drinking water. *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

NO IMMEDIATE ACTION REQUIRED AT THIS TIME:

However, in the event that a routine sample is FECAL/ECOLI positive follow the steps below.

1. **Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the CDO at 614-728-3868
2. **Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas
 - Send to parents or guardians of children at schools or day care facilities
 - Another delivery method approved in writing by the director
 - Posted notices must remain in place for as long as the violation exists.
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
 - **NOTE: Issuance of a Public Notice must be repeated every 30 days** for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice stating the corrective measures completed to date must be submitted to the Ohio EPA.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov


Geoffrey Burns

Page -2-

3. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
4. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.
5. **Discontinue the Water Use Advisory** – The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
6. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 614-728-3871.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures: Tier 1 Public Notification
Public Notice Instructions and Verification Form

c: Fairfield County Health Department
Information Management Section, DDAGW/CO
District File Copy

MB/ct 4537412(MORvio)Jan2011