



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 28, 2008

Re: **Fairfield County
Mom & Me Academy, Ltd
Non-Transient Non-Community
PWS ID #2350812**

Mom & Me Academy, Ltd
5525 Coakley Road
Carroll, OH 43112

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Lead and Copper

Your public water system is in violation of Rule 3745-81-80 through 3745-81-89 of the Ohio Administrative Code for failure to comply with the lead and copper monitoring requirements:

Monitoring Period:	January 1 - June 30, 2008
Required Sampling:	5 samples for each lead and copper
Sample Results Submitted:	None

Actions required as a result of the above violation	
Step 1	Collect and analyze the required number of lead and copper tap samples during July 1 - December 31, 2008. Based upon the reported population, you are required to collect a minimum of 5 lead and copper samples. Report results on the enclosed forms 5105, 5106 and 5107 by January 10, 2009.
Step 2	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods</p> <ol style="list-style-type: none"> continuous posting, mail, or other direct delivery; and if necessary, the system must also use any other method reasonably calculated to reach all persons <p>The language in <i>italics</i> on the attached public notice is mandatory and must be included as written.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Mom & Me Academy, Ltd
Page -2-

If you have any questions, please contact me at (614) 728-3866.

Sincerely,

A handwritten signature in cursive script that reads "Susan Applegate".

Susan Applegate
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Fairfield County Health Department
Toni Buchanan, DDAGW/CO
CDO File