



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

June 4, 2009

Re: Fairfield County
Shalom UMC
Non-transient non-community System
PWS ID: 2348012

Gary Collins
Shalom UMC
4925 Plum Road NW
Carroll, OH 43112

SUBJECT: Violations of Ohio Administrative Code (OAC)

Dear Mr. Collins:

This is to inform you that in accordance with OAC 3745-81-90(C)(4) and 3745-83-01(G)(8)(a), Shalom United Methodist Church is in violation for:

1. Failure to notify the Ohio EPA in writing that the hardness level was increased to a level of 80-100 mg/L (as CaCO₃) by April 31, 2009.
2. Failure to notify the Ohio EPA of the results of the total hardness analysis as performed by a state certified laboratory beginning in May, 2009. Enclosed are monthly report forms for reporting monthly hardness levels. Use of these forms will help ensure accurate tracking compliance with this requirement.

Within 10 days of the date of this letter, compliance with these requirements is requested.

As a reminder, two consecutive six month sets of lead and copper samples must be collected and reported on 5105, 5106 and 5107 forms (previously provided).

1. Collect five first draw lead and copper samples by no later than June 30, 2009, and report them to our office by July 10, 2009.
2. Also, collect five first draw lead and copper samples between July 1-December 31, 2009, and report them to our office by January 10, 2010.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Gary Collins
Shalom UMC
Page -2-

If you need assistance or more reporting forms, I can be reached at (614) 728-3864.

Sincerely,

A handwritten signature in cursive script that reads "Carolyn O'Neal".

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

Enclosures: Green MORs

c: Fairfield County Health Department
Mark Boden, DDAGW/CDO
Tiara Bryant, DDAGW, CDO
Carolyn O'Neal, CDO file copy

CO/slw ShalomVia