



STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

**NOTICE OF VIOLATION – ACTION REQUIRED**

February 1, 2008

Re: **Fairfield County  
Small Wonders Day Care PWS  
Non Transient Non Community  
PWS ID: OH2340812**

2K Limited  
1245 East Slate Ridge Drive  
Canal Winchester, OH 43110

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During Fourth Quarter of 2007 (Monthly)**

Small Wonders Day Care PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Non Transient Non Community** column.

Public Community	Transient or Non Transient Non Community
<ul style="list-style-type: none"> <li>• Mail or other direct delivery to each customer</li> <li>• If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting</li> </ul>	<ul style="list-style-type: none"> <li>• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;</li> <li>• Mail or other direct delivery to each customer</li> <li>• Send to parents or guardians of children at schools or day care facilities</li> <li>• E-mail, newsletters or newspaper</li> </ul>
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Small Wonders Day Care PWS


January 29, 2008

Page 2

3. **Complete the enclosed verification form within ten (10) days of issuing the Public Notice** and mail it to Ohio EPA - Central District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7). Five routine samples must be collected during the month of January 2008.

If you have any questions, contact this office at (614) 728-3866.

Sincerely,



Susan Applegate  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

c: Fairfield County Health Department  
Central District Office Files