

SIGNATURE RECEIVE

OH2566112

AHMADIYYA MOSQUE

1/27/2009

1/30/09



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4450 0812

January 27, 2009

**Re: Franklin County
Ahmadiyya Mosque
PWS ID: OH2566112
TP ID: 2562121
Transient Water System**

Mr. Kalim Khan
Ahmadiyya Mosque
3371 Lake Cumberland Way
Grove City, OH 43123

Dear Mr. Khan:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that the Ahmadiyya Mosque has not complied with requirements issued during this Agency's last survey performed on July 16, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated July 23, 2008 to respond in writing no later than 45 days, with time frames for completion of the following items:

1. Fill out the sample siting plan and maintain it on site. Send me a copy of the completed plan.
2. Grade the soils around the well head such that surface water will flow away from the casing. Keep the vegetation low near the casing.
3. Use salt in your softener that has been properly certified to ANSI/NSF standard 60.


You must respond within 15 days of the date of this letter with the required information. Failure to comply may result in further enforcement action.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Mr. Larry Borrer
Roth Produce Company
Page -2-

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871.

Sincerely,

A handwritten signature in black ink, appearing to be 'Mark Boden', written over the word 'Sincerely,'.

Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Franklin County Health Department
Dave Evans, DDAGW/CO
File

MB/cl Ahmadiyya Mosque-RTC

