

SIGNATURE RECEIVED
8/27/08
OhioE



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4450 3110

August 25, 2008

Re: **Franklin County
Camp Ken-Jockey Pool
PWS ID: OH2553112
TP ID: 2554192
Transient Water System**

Ms. Gina Williams
Girl Scouts-Seal of Ohio Council
1700 Watermark Drive
Columbus, OH 43215-1097

Re: Notice of Violation for Failure to Respond to a Significant Deficiency

Dear Ms. Williams:

This letter is notification that the Camp Ken Jockey Pool has not complied with requirements issued during this Agency's last survey performed on May 9, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated July 8, 2008 to respond in writing no later than 45 days, with time frames for:

- 1) Installing a vented, screened well cap;
- 2) Sending a copy of your completed sample siting plan, and
- 3) Using only NSF/ANSI certified salt in your softener.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action. You may notify me in writing via email at mark.boden@epa.state.oh.us or use the fax number or address provided in the letterhead.

If you have any questions, please contact me at 614-728-3871.

Sincerely,


Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: **Franklin County Health Department
DDAGW/CO**

MB/ct CampKenJockeyRTC

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

