

11/7/07



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

November 1, 2007

**Re: Franklin County
Makoy Center, Inc.
Transient Non-Community
PWS ID #2557212
CERTIFIED 91 7108 2133 3932 4450 7620**

President
Makoy Center, Inc.
5462 Center Street
Hilliard, OH 43026

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE - E. coli positive and a Monthly)

Your public water system incurred an **acute** and **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 24, 2007.

An acute violation occurs when:

- a repeat sample is either fecal or E. coli-positive; or
- a repeat sample is total coliform-positive following a fecal or E. coli positive routine sample.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	Within 24 hours , consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system: The language in italics on the attached public notice is mandatory and must be included as written.
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

President
Makoy Center, Inc.
Page -2-

Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in November 2007.
--------	--

If you have any questions, please contact me at (614) 728-3874.

Sincerely,



Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Franklin County Health Department
Toni Buchanan, DDAGW/CO
CDO File
Operations Manager, Makoy Center, Inc.