



STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 31, 2007

Re: **Franklin County
New Life Baptist Church
Transient Non-Community
PWS ID #2556112**

Pastor
New Life Baptist Church
5027 Avery Road
Dublin, OH 43002

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	April - June 2007
Required Coliform Sampling:	At least 1 sample each calendar quarter.
Sample Results Submitted:	NONE

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. Continuous posting, mail, or other direct delivery; and 2. If necessary, the system must also use any other method reasonably calculated to reach all persons. <p>The language in <i>italics</i> on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.</p>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

Pastor
New Life Baptist Church
Page -2-

If you have any questions, please contact me at (614) 728-3874.

Sincerely,

A handwritten signature in cursive script that reads "Ray Shesky". The signature is written in black ink and is positioned above the typed name.

Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Franklin County Health Department
CDO File