

SIGNATURE

OH2557012 RAGER ROAD CHURCH OF CHRIST PWS

22 08/22/07 A



State of Ohio Env

Central District Office

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

August 22, 2007

**Re: Franklin County
Rager Road Church Of Christ
Transient Non-Community
PWS ID #2557012
CERTIFIED #91 7108 2133 3932 4450 9280**Pastor
Rager Road Church Of Christ
5775 Rager Road
Canal Winchester, OH 43110**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July - September 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 2	Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.). The language in italics on the attached public notice is mandatory and must be included as written.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days of the issuance of the public notice to the Central District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in August 2007.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Pastor
Rager Road Church Of Christ
Page -2

If you have any questions, please contact me at (614) 728-3874.

Sincerely,

A handwritten signature in black ink that reads "Ray Shesky". The signature is written in a cursive style with a large, prominent "R" at the beginning.

Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO
Franklin County Health Department
CDO File

RS/nsm 2557012 NOV22 July-Sept. 2007