

2/10/09



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4450 0591

February 2, 2009

Re: **Franklin County
Reese Community Baptist Church
PWS ID: OH2566912
TP ID: 2562263
Transient Water System**

Chris Yates
Reese Community Baptist Church
5133 Dexter Court
Obetz, OH 43207

Dear Mr. Yates:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that Reese Community Baptist Church has not complied with requirements issued during this Agency's last survey performed on October 27, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated November 6, 2008 to respond in writing no later than 45 days, with time frames for completion of the following items:

REQUIREMENTS

1. Fill out the sample siting plan left during the survey and maintain it on site. Send me a copy of the completed plan (first page only). I have enclosed another copy for your benefit.
2. Maintain all records of your drinking water system on site. This would include your license to operate (LTO) a public drinking water system (will be sent under separate cover), plan approvals (your new well should be going through this at this time), the well log (from the driller), owners/operations manuals for the pump and pressure tank, results from the laboratories, the sample siting plan mentioned above, operation and maintenance records, and any correspondence received from this office.

You must respond within 15 days of the date of this letter with the required information. Failure to comply may result in further enforcement action.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Chris Yates
Reese Community Baptist Church
Page -2-

On September 25, 2008, I sent you a letter that required you to submit detail plans on your new water system (see item #8). Although we've been in communication, it has been 4 months since the well was drilled, submit your plans promptly. If you or Ike desire a meeting before submitting your plans, contact Jose Quinones at 728-3869, he will be responsible for reviewing your submission.

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

Enclosure: Bacteriological Sample Siting Plan

c: Franklin County Health Department
Dave Evans, DDAGW/CO
File

MB/ct ReeseCBC-RTC