



State of Ohio Enviror

OH2555812 THE DARBY HOUSE

22 10/07/10



\* 0 H 2 5 5 5 8 1 2 8 1 6 3 9 0 4 \*

Central D

MAILING ADDRESS

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

**NOTICE OF VIOLATION - ACTION REQUIRED**

October 7, 2010

**Re: Franklin County  
The Darby House  
Non-Community, Transient  
PWS ID: OH2555812**

Ashley Hoye  
925 Darby Creek Drive  
Galloway, OH 43119

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During August 2010 (Monthly)**

The Darby House is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Mail or other direct delivery to each customer;
  - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice and mail it to Ohio EPA - CDO.** Include a copy of each notice distributed, published or posted.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Ashley Hoye  
Page -2-

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 614-728-3871 .

Sincerely,



Mark Boden  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

c: Franklin County Health Department  
Information Management Section, DDAGW/CO  
District File Copy