



State of Ohio Environmental Protection Agency 6 6 8 1 2 2 2 2 0 9 N O V \*

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049**CERTIFIED MAIL # 91 7108 2133 3932 4450 0621**

February 2, 2009

**Re: Franklin County  
The Garden Inn  
PWS ID: OH2566812  
TP ID: 2562238  
Transient Water System**Mr. Steve Emmons  
The Garden Inn  
6091 Cleveland Avenue  
Columbus, OH 43231

Dear Mr. Emmons:

**Subject: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that The Garden Inn has not complied with requirements issued during this Agency's last survey performed on July 17, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated July 23, 2008 to respond in writing no later than 45 days, with time frames for completion of the following items:

**REQUIREMENTS**

1. Fill out the sample siting plan and maintain it on site. Send me a copy of the completed plan.
2. Follow your sampling schedule as outlined in your 2009 Contaminant Monitoring Schedule.
3. Install a pressure gauge on the water system.


You must respond within 15 days of the date of this letter with the required information. Failure to comply may result in further enforcement action.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Mr. Steve Emmons  
The Garden Inn  
Page -2-

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871.

Sincerely,

A handwritten signature in black ink, appearing to read 'Mark Boden', written in a cursive style.

Mark Boden  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Franklin County Health Department  
Dave Evans, DDAGW/CO  
File

MB/ct TheGardenInn-RTC