

8/27/08



State of Ohio Environment \* 0 H 4 2 4, 0 6 1 2 B 2 5 2 0 0 8 N O V \*

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.usP.O. Box 1049  
Columbus, OH 43216-1049**CERTIFIED MAIL # 91 7108 2133 3932 4450 3097**

August 25, 2008

**Re: Knox County  
Breeze On 3 Public Water System  
Transient Noncommunity Water System  
PWS ID: 4240612  
TP ID: 4255440**Ms. Mary Lee Kirk  
15121 Wooster Road  
Mount Vernon, OH 43050**Re: Notice of Violation for Failure to Respond to a Significant Deficiency**

This letter is notification that the Breeze Inn has not complied with requirements issued during this Agency's last survey performed on May 9, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated May 15, 2008 to respond in writing no later than 45 days, with time frames for:

- 1) Installing a vented, screened well cap;
- 2) Sending a copy of your completed sample siting plan;
- 3) Sending us a copy of the public notice for total coliform 1<sup>st</sup> quarter of 2008;
- 4) Keeping the vegetation trimmed around the well head, and
- 5) not chlorinating the well before drawing a total coliform sample.

We have received payment of your LTO fee for this year.

The water system must respond in writing within 15 days from the date of this letter with the required information. Failure to comply may result in further enforcement action. You may notify me in writing via email at [mark.boden@epa.state.oh.us](mailto:mark.boden@epa.state.oh.us) or use the fax number or address provided in the letterhead.

If you have any questions, please contact me at 614-728-3871.

Sincerely,

Mark Boden  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Officec: Knox County Health Department  
DDAGW/CO

MB/ct BreezeOn3RTC

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



[The page contains extremely faint and illegible text, possibly bleed-through from the reverse side of the document.]