

2/3/09



State of Ohio Environment



* 0 H 4 2 3 0 4 1 2 1 3 0 2 0 0 9 N O V *

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED MAIL # 91 7108 2133 3932 4450 0720

January 30, 2009

**Re: Knox County
Butler's Restaurant
PWS ID: OH4230412
TP ID: 4255386
Transient Water System**

Ms. Sue Butler
Butler's Restaurant
P.O. Box 48
25913 New Guilford Road
Bladensburg, OH 43005

Dear Ms. Butler:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that Butler's Restaurant has not complied with requirements issued during this Agency's last survey performed on November 13, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated December 11, 2008 to respond in writing no later than 45 days, with time frames for completion of the following items:

REQUIREMENTS

1. Please fill out the sample siting plan left during the survey and maintain it on site. Send me a copy of the first page of the completed plan.
2. Please install a new well cap on the well that is screened and vented and meets the requirements of Water System Council Pitless Adapter Standard PAS-97 as required by Ohio Administrative Code rule 3745-9-5. The standard the rule references can be found on the website at: <http://www.watersystemscouncil.org/upload/standards/pitless04printed.pdf>.
3. Please maintain all water system records on site, including owners manuals for pump and treatment units, and note the date and nature of any repairs or remedial actions, including replacement of system components.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ms. Sue Butler
Butler's Restaurant
Page -2-

4. Verify that the casing is all PVC. If there is a PVC casing extension on the original steel well casing, a steel casing extension must be either welded or threaded onto the original well casing.

You must respond within 15 days of the date of this letter with the required information. Failure to comply may result in further enforcement action.

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Knox County Health Department
Dave Evans, DDAGW/CO
File