



State of Ohio En



STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

December 11, 2009

Re: **Knox County  
Columbia Gas Of Ohio PWS  
Transient Non-Community  
PWS ID #OH4238112**

Columbia Gas Of Ohio PWS  
200 Civic Center Drive  
Columbus, OH 43215-011

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Lead and Copper**

Your public water system is in violation of Rule 3745-81-80 through 3745-81-89 of the Ohio Administrative Code for failure to comply with the lead and copper monitoring requirements:

<b>Monitoring Period:</b>	<b>June 1 -September 30, 2009</b>
<b>Required Sampling:</b>	<b>5 samples for each lead and copper</b>
<b>Sample Results Submitted:</b>	<b>None</b>

<b>Actions required as a result of the above violation</b>	
<b>Step 1</b>	Collect and analyze the required number of lead and copper tap samples during June 1 -September 30, 2010. Based upon the reported population, you are required to collect a minimum of 5 lead and copper samples. Ohio EPA recommends submitting the Consumer Notice Verification Form and Example Notice with Forms EPA 5105, EPA 5106 and EPA 5107 along with sample results by October 10, 2010.
<b>Step 2</b>	<p>Within 30 days issue public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods</p> <ol style="list-style-type: none"> <li>continuous posting, mail, or other direct delivery; and</li> <li>if necessary, the system must also use any other method reasonably calculated to reach all persons</li> </ol> <p>The language in italic on the attached public notice is mandatory and must be included as written.</p>

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Columbia Gas Of Ohio PWS  
Page -2-

If you have any questions, please contact me at (614) 728-3871.

Sincerely,

A handwritten signature in cursive script that reads "Carol - Mark for Mark Boden".

Mark Boden  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Knox County Health Department  
Toni Buchanan, DDAGW/CO  
CDO File

MB/ct 4238112 52 2009