

SIGNATURE RECEIVED

FILE COPY

OH4243312 JOY OF LIVING MINISTRIES INC PWS

25 12/24/07

1/17/08



State of Ohio



Central District Office

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

January 8, 2008

Re: **Knox County**
Joy Of Living Ministries, Inc.
Transient Non-Community
PWS ID #4243312
CERTIFIED MAIL # 91 7108 2133 3932 4450 7446

Joy Of Living Ministries, Inc.
1067 Foxhaven Drive
Ashland, OH 44805

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE, MONTHLY & Failure to Monitor with four repeat samples)

During October 2007, your public water system incurred **acute** and **monthly** violations of rule 3745-81-14 of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC.

Acute and monitoring violations occur when four (4) total coliform bacteria repeat samples are not collected within the required time.

A monthly violation occurs when more than one or greater than five percent of your samples within the month are total coliform-positive.


Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance rule with 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in November 2007.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Joy of Living Ministries, Inc.
Page -2-

If you have any questions, please contact me at (614) 728-3866.

Sincerely,



Susan Applegate
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Knox County Health Department
Toni Buchanan, DDAGW/CO
CDO File

SA/cl 4243312 NOV21 22 25or26 October 2007