

SIGNATURE

OH4243312 JOY OF LIVING MINISTRIES INC PWS

10/14/07

25 10/01/07 A



State of Ohio Ei

Central District Office

35:

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

October 1, 2007

Re: Knox County  
Joy Of Living Ministries, Inc.  
Transient Non-Community  
PWS ID #4243312  
CERTIFIED #91 7108 2133 3932 4450 9600

Joy Of Living Ministries, Inc.  
1067 Foxhaven Drive  
Ashland, OH 44805

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE, MONTHLY & Failure to Monitor with four repeat samples)**

During September 2007, your public water system incurred **acute** and **monthly** violations of rule 3745-81-14 of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC.

**Acute and monitoring violations** occur when four (4) total coliform bacteria repeat samples are not collected within the required time.

**A monthly violation** occurs when more than one or greater than five percent of your samples within the month are total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance rule with 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in October 2007.
--------	---

If you have any questions, please contact me at (614) 728-3866.

Sincerely,



Susan Applegate  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures

c: Toni Buchanan, DDAGW/CO  
Knox County Health Department  
CDO File