

2/5/09



State of Ohio Environment * 0 H 4 2 3 6 4 1 2 2 2 0 0 9 N O V *

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049**CERTIFIED MAIL # 91 7108 2133 3932 4450 0607**

February 2, 2009

**Re: Knox County
Table Rock Golf Club
Transient Noncommunity Water System
PWSID: 4236412**Mr. Jim Butler
Table Rock Golf Club
3005 Wilson Road
Centerburg, OH 43011

Dear Mr. Butler:

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that Table Rock Golf Club has not complied with requirements issued during this Agency's last survey performed on August 25, 2008, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in correspondence dated August 28, 2008 to respond in writing no later than 45 days, with time frames for completion of the following items:

REQUIREMENTS

1. Please install a new well cap on the well that is screened and vented and meets the requirements of Water System Council Pitless Adapter Standard PAS-97 as required by Ohio Administrative Code rule 3745-9-5. The standard the rule references can be found on the web at:
<http://www.watersystemscouncil.org/upload/standards/pitless04printed.pdf>.
2. Once you have picked out a lab, fill out the sample siting plan I left you and maintain it on site, and please send a copy to us.
3. Please have the double check valve on the line to the sprinkler head in the utility room checked annually, and ensure the inspection tag remains on the valve.


You must respond within 15 days of the date of this letter with the required information. Failure to comply may result in further enforcement action.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Mr. Jim Butler
Table Rock Golf Club
Page -2-

Let me know if you have any questions or issues regarding your public water system. My phone number is (614) 728-3871.

Sincerely,

A handwritten signature in black ink, appearing to be 'Mark Boden', written in a cursive style.

Mark Boden
Environmental Specialist
Division of Drinking and Ground Waters
Central District Office

c: Knox County Health Department
Dave Evans, DDAGW/CO
File

MB/ct TableRockGC-RTC